

MINIMUM CLEARANCE DISTANCES WHILE TRAVELING WITH NO LOAD

| Voltage (kV) | Minimum Clearance Distance (feet) |
|------------------|-----------------------------------|
| Up to 0.75 kV | 4 ft |
| >.75 to 50 kV | 6 ft |
| >50 to 345 kV | 10 ft |
| >345 to 750 kV | 16 ft |
| >750 to 1,000 kV | 20 ft |
| >1,000 kV | *Determined by the utility/owner |

*Established by owner or registered professional engineer/qualified person.